


HMF EXPRESS



Dutch Doors

Max Opening Size	Opening Type	Profile	Max Gauge Steel	Edge Const	Core	Under Cut	Gap Between Leaves	Shelf	Max Leaf Height	Max Fire Rating
4-0 x 7-2	Sgl	Flush Only	16	Butt	Poly	11/16"	7/32"	Half Only	43"	3 Hour

Notes: Each leaf will receive a UL fire label

Horizontal astragal required - mounted to top leaf with #8 x 1/2" SMS

Half shelf permitted - must not interfere with astragal operation

No lights or louvers permitted

1 3/4" thick only

161 or mortise lock required on each leaf with latchbolt and lipped strike

Alternate method is latching top leaf with 161 to bottom leaf with lipped strike

Max rating 90 minute with UL listed door viewer in top leaf

Top leaf must be self closing which may require additional hardware if hold open is needed

Minimum nominal height 6' - 8"